

REA Energy Cooperative, Inc.

POLICY BULLETIN NO. C-2B

SUBJECT: Line Clearance Specifications

POLICY: I. Primary Lines

A. Horizontal Clearance Specifications

1. Standard REA Energy clearances are 20 feet from center of overhead primary lines, totaling forty (40) feet from ground to sky, and 7.5 feet from center of primary underground lines, totaling fifteen (15) feet. Members are not permitted to erect any structures, pools, or other obstructions within above clearances.
2. Horizontal clearances must comply with NESC (National Electric Safety Code), where applicable as determined by the Cooperative.

B. Vertical Clearance Specifications

1. Members are not permitted to erect any structures, pools, or other obstructions directly beneath existing primary lines owned by the Cooperative.
2. Any member who builds a new structure under an existing primary line will be billed the actual cost for the Cooperative to move the line to meet the clearance specifications.
3. The Cooperative will not set a meter on any new structure built under an existing primary line, until the line has been relocated and all of the costs associated with the line relocation have been paid by the member.

II. Secondary and Service Lines

- A. Clearances must comply with NESC (National Electric Safety Code) and REA Energy Cooperative, Inc. Member Requirements for Electric Service and Upgrades (www.reaenergy.com)

RESPONSIBILITY: It shall be the responsibility of the President & CEO to administer this policy.

AUTHORITY: Adoption of this bulletin by official action of the Board of Directors at a regular meeting on November 25, 2014.

This policy supersedes and cancels all other policies which relate to the subject matter herein and which may be in conflict herewith.

DATE: November 25, 2014

SECRETARY: /s/ Robert P. Neese

Adopted June 25, 2001
Revised October 29, 2002
Revised April 28, 2009
Revised April 28, 2009
Revised November 25, 2014

